

Water and Sanitary condition certificate

No. Q.....

Date 15/10/2025

It is certified that an inspection team headed by A.E. P.H.E. Sub. Div. SHEOPUR (M.P.)

(Name of officers with designation) from Executive Officer, Municipality, Sheopur 476337 on 15/10/2025 and found that Bandi Chhor Academy, Sheopur, Pali Road Sheopur-476337, (Bandi Chhor Academy, Sheopur) has safe drinking water facilities for the students and members of the staff of the institution and is maintaining the hygienic conditions in the school building and the campus as per norms prescribed by the government.

Number of water purifier/R.O. installed in the school	01
Number of toilets available in the working condition	28
Number of water cooler	02
Sanitation of the school campus	satisfactory

Signature with

Seal Assistant Engineer
P.H.E. Sub. Division
Sheopur (M.P.)

Name: O. P. Nagar

Designation: Assistant Engineer
P.H.E. Sub. Div. Sheopur (M.P.)

To

Bandi Chhor Academy, Sheopur

Pali Road, Soin Kalan

Dist. Sheopur-476337

Madhya Pradesh (INDIA)

Manager
Bandi Chhor Academy
Sheopur (M.P.)

Principal
Bandi Chhor Academy
Sheopur (M.P.)

DISTRICT WATER TESTING LABORATORY

Public Health Engineering Department (M.P.)

NO/AE/Lab/PHE / Sub Dn.Sheopur


Dated -----14-10-2025

Particulars of Sender - Asstt. Eng. PHE Sub Dn. Ref No..... and Drinking						
PERTICLARS OF SAMPLE		Action and details of sample			SAMPLE NAME	
Sample No -290/19		Bandi Chhor Academy Sheopur			1.Bandi Chhor Academy Sheopur	
PRATICULARS OF BE FILLED IN LABORATORY						
Date of Receipt :-		13-10-2025			Time of Receipt 06:05PM	
Lab Reference No.		-			Tested on :- 14-10-2025	
NATURE OF STUDY CHEMICAL & BACTERIOLICAL ANALYSIS						
		Unit	As per Bis - 10500 for Drinking water		Result	
			Requirement (Desirable limit)	permissible limit in the absence of attemate source	1	2
PHYSICAL TESTS						
1-	Temperature	OC	-----	-----	-	-
2-	Turbidity	NTU	1.0	5.0	1.2	-
3-	Colour	Hazen units	5	15		-
4-	Odour	-	Unobjectionable	Unobjectionable		
5-	PH	PH Scle	6.52- 8.5	No Relaxation	7.2	-
6-	Coducitivity 25 °C	Micromhos per cm ²			-	-
7-	Phenolphthaleinalkatinity	Mg/l			-	-
8-	Total Alkalinty as Caco ₃	Mg/l	200	600	342	-
9-	Chloride as Cl	Mg/l	250	1000	83	-
10	Nitrate as No ₃	Mg/l	45	45	4	-
11	Total Hardness as Caco ₃	Mg/l	200	600	380	-
12	Calcium Hardness as Cl	Mg/l	75	200	93.6	-
13	Magnesium Hardness as Mg		30	100	35.04	-
14	Total solid	Mg/l			-	-
15-	Total Dissolved solids	Mg/l	500	2000	394	-
16-	Total Suspended solids	Mg/l			-	-
17-	Iron	Mg/l	0.3	1.0	0.2	-
18-	Sulphate as So ₄	Mg/l	200	400	-	-
19-	Fluride as F	Mg/l	1	1.5	0.2	-
Other Chemicals Test					-	-
Bacteriological					00	-



Manager
Bandi Chhor Academy
Sheopur (M.P.)

CHEMIST
Chemist
PHE (LAB) SHEOPUR (M.P.)
PHED Division Sheopur



Principal
Bandi Chhor Academy
Sheopur (M.P.)